


REPORT

TRUESDAIL LABORATORIES, INC.



CHEMISTS - MICROBIOLOGISTS - ENGINEERS
RESEARCH - DEVELOPMENT - TESTING

14201 FRANKLIN AVENUE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 225-1564
CABLE: TRUELABS

CLIENT **Douglas Aircraft Company**
Internal Mail Code 211-46
3855 Lakewood Boulevard
Long Beach, California 90846
Attention: Kathleen Faretta

DATE May 11, 1990

RECEIVED April 12, 1990

SAMPLE **Monthly Storm Drain Inspection - April, 1990**
P.O. No.: T & M 23465C

LABORATORY NO. 35574-2


INVESTIGATION **As requested by the CRWQCB for NPDES
permit number CA0001414**


RESULTS

A representative of Truesdail Laboratories, Inc., tested the storm drain discharge on April 12, 1990, at the Douglas Long Beach facility (003) and Torrance facilities. The discharge was tested for flow rate, pH, and temperature. The results are as follows:

<u>Sample I.D.</u>	<u>Date</u>	<u>Time</u>	<u>Flow-gpd</u>	<u>Temp, °F</u>	<u>pH, units</u>
Torrance	4/12/90	12:35	297	52	6.9

Respectfully submitted,
TRUESDAIL LABORATORIES, INC.


Gregory W. Everett, Proj. Mgr.
Industrial Waste



This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these Laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from these Laboratories.